




	<b>SELF TEST</b>
	<b>DALI</b>

- EN60598-1
- EN60598-2-22
- EN55015
- EN61547
- EN61000-3-2
- STEEL



To specify a wireless product variant for use with Philip Payne SpectroXT Emergency Lighting System from this range simply replace gear suffix code with XT.

**Specification**

<b>Voltage</b>	<b>230v</b>
<b>IP</b>	<b>20</b>
<b>Weight</b>	<b>1.5kg</b>
<b>Gear Options</b>	<b>230v central Supply 3hr Non-Maintained 3hr Maintained 3hr Self Test 3hr DALI</b>

**PART NUMBERS**

250SLLA	230v AC/DC	Central Supply
250SLDA	230v AC/DC	Central Supply DALI
250SLLM	3hr Self Contained	Maintained/ Non-Maintained
250SLYL	3hr Self Contained	Self Test
250SLDL	3hr Self Contained	DALI

**FINISH OPTIONS**

<b>R</b> Satin Chrome	<b>W</b> RAL 9016
<b>C</b> Polished Chrome	<b>G</b> RAL 9006
<b>B</b> Polished Brass	<b>K</b> RAL 9005
<b>D</b> BMA	<b>V</b> Penny Bronze

Products should be suffixed with appropriate code. For example: **250SLLMW** for white finished product.