

PHILIP PAYNE | TYKH 870



			DALI		
NM 		SELF TEST			

EN60598-1	EN61547
EN60598-2-22	EN61000-3-2
EN55015	PC ABS

			Wall to Luminaire	Luminaire to Luminaire	Lumen Output	Wattage	Drive Current	Dimensions	Mains	DALi Mains	3hr NM	3hr NM Self Test	3hr NM DALi
TYKH870	1.2m escape route with 10.8 Lux average and 1 Lux minimum. 8m ceiling	NFPA101	3.5m	8.2m	545	4 Watts	700mA		TYKH870LA	TYKH870DA	TYKH870LN	TYKH870YS	TYKH870DS
	Open Area with 10.8 Lux average and 1 Lux minimum. 8m ceiling	NFPA101	2.0m	7.2m	545	4 Watts	700mA						