

				EN60598-1	EN61547
				EN60598-2-22	EN61000-3-2
				EN55015	PC ABS

# TYKE 880 | PHILIP PAYNE



			Wall to Luminaire	Luminaire to Luminaire	Lumen Output	Wattage	Drive Current	Dimensions
TYKA880XT	2m Wide escape route with 1 lux on centreline	BS5266	5.2m	12.3m	200	3 Watts	800mA	
	Open Area with 0.5 Lux minimum excluding 0.5m border	BS5266	4.8m	10.6m	200	3 Watts	800mA	
TYKC880XT	2m Wide escape route with 1 lux on centreline	BS5266	6.7m	17.5m	175	3 Watts	800mA	
	Open Area with 0.5 Lux minimum excluding 0.5m border	BS5266	N/A	N/A	175	3 Watts	800mA	
TYKE880XT	2m Wide escape route with 1 lux on centreline	BS5266	3.7m	8.5m	190	3 Watts	800mA	
	Open Area with 0.5 lux minimum excluding 0.5 border	BS5266	3.5m	7.2m	190	3 Watts	800mA	
TYKP880XT	2m Wide escape route with 1 lux on centreline	BS5266	3.7m	8.5m	190	3 Watts	800mA	
	Head assembly IP rated beneath ceiling *	BS5266	3.5m	7.2m	190	3 Watts	800mA	