





355mm




\*FIXING HOLES Ø4mm














(USL=UNSWITCHED LIVE, SL=SWITCHED LIVE)




MM3









Continual operation at mains voltages in excess of the rated voltage will reduce LED and expected gear life.

This luminaire uses plastic components in its construction and when installed in environments containing chemicals, degradation may occur.

Please contact our Technical Department for advice.

# Modifications

Philip Payne products should not be modified.

Any modification may render the product unsafe and will invalidate any Safety/Approval marks.

Philip Payne will not accept any responsibility for any modified products or for any damage caused as a result of their modification.

# **Monthly and Annual Tests**

Monthly and Annual tests should be carried out in accordance with BS EN 50172:2004, 7.2.

Testing can be carried out by using a sub circuit isolator or by switching off the lighting circuit at the circuit breaker (not for AutoTest or DALI versions).

Battery pack shall be replaced if the specified 3 hour duration is not met.

For replacement battery pack contact Philip Payne Ltd.

The light source of this luminaire is not replaceable; when the light source reaches its end of life the whole luminaire shall be replaced.

# **Important-Safety**

Before carrying out any servicing on this luminaire, ensure that the mains supply is fully isolated. Disconnect luminaire before insulation testing of the installation.



# Philip Payne Ltd

A SUBSIDIARY OF F.W. THORPE PLC

Thornhill Road, Solihull, B91 2HB, England. 0121 705 2384 Tel:

Fax: 0121 711 2469 e-mail: mail@philippayne.co.uk Website: http://www.philippayne.co.uk Philip Payne Ltd registered in England No. 1361523









ISO9001 FM55077

21LFT079\_4

# **Emergency Bulkhead** Surface Ceiling

IP65

Class 1

( (


**Lantis Specto-XT** 

Downlighter features	Supply voltage	Part No.
MM3 Specto-XT	220-240V DC/AC 50/60 Hz	LANT110XT

# Connections

(USL=UNSWITCHED LIVE, SL=SWITCHED LIVE)








Do not stare at operating lamp. It may be harmful to the eyes.

# Orientation (Wall Mounted)

# Specto-XT Transceiver



# NOTICE TO CONTRACTOR - PLEASE PASS THIS LEAFLET TO THE END-USER.

# **Important-Safety**

Before carrying out any servicing on this luminaire, ensure that the mains supply is fully isolated.

Disconnect luminaire before insulation testing of the installation.



# **Philip Payne Ltd**

A SUBSIDIARY OF F.W. THORPE PLC Thornhill Road, Solihull, B91 2HB, England.

Tel: 0121 705 2384
Fax: 0121 711 2469
e-mail: mail@philippayne.co.uk
Website: http://www.philippayne.co.uk
Philip Payne Ltd registered in England No. 1361523



ISO9001









21LFT064 2


Downlighter features	Supply voltage	Part No.
NM3	220-240V AC 50/60 Hz	LANT300LN
NM3 AutoTest DALI	220-240V AC 50/60 Hz	LANT300DS


# Dimensions




# **Connections**

















# **Cleaning Instructions**



# Operation and Maintenance

Continual operation at mains voltages in excess of the rated voltage will reduce LED and expected gear life.

This luminaire uses plastic components in its construction and when installed in environments containing chemicals, degradation may occur. Please contact our Technical Department for advice.

## Modifications

Philip Payne products should not be modified.

Any modification may render the product unsafe and will invalidate any Safety/Approval marks.

Philip Payne will not accept any responsibility for any modified products or for any damage caused as a result of their modification.

#### **Monthly and Annual Tests**

Monthly and Annual tests should be carried out in accordance with BS EN 50172:2004, 7.2.

Testing can be carried out by using a sub circuit isolator or by switching off the lighting circuit at the circuit breaker (not for AutoTest or DALI versions). Battery pack shall be replaced if the specified 3 hour duration is not met.

For replacement battery pack contact Philip Payne Ltd.

The light source of this luminaire is not replaceable; when the light source reaches its end of life the whole luminaire shall be replaced.

#### **Important-Safety**

Before carrying out any servicing on this luminaire, ensure that the mains supply is fully isolated.

Disconnect luminaire before insulation testing of the installation.



# **Philip Payne Ltd**

A SUBSIDIARY OF F.W. THORPE PLC Thornhill Road, Solihull, B91 2HB, England.

Tel: 0121 705 2384
Fax: 0121 711 2469
e-mail: mail@philippayne.co.uk
Website: http://www.philippayne.co.uk
Philip Payne Ltd registered in England No. 1361523











ISO9001 FM55077

21LFT077\_1




# NOTICE TO CONTRACTOR - PLEASE PASS THIS LEAFLET TO THE END-USER.






# Connections



(DALI)





#### Operation and Maintenance

Continual operation at mains voltages in excess of the rated voltage will reduce LED and expected gear life.

This luminaire uses plastic components in its construction and when installed in environments containing chemicals, degradation may occur.

Please contact our Technical Department for advice.

#### Modifications

Philip Payne products should not be modified.

Any modification may render the product unsafe and will invalidate any Safety/Approval marks.

Philip Payne will not accept any responsibility for any modified products or for any damage caused as a result of their modification.

## **Monthly and Annual Tests**

Monthly and Annual tests should be carried out in accordance with BS EN 50172:2004, 7.2.

Testing can be carried out by using a sub circuit isolator or by switching off the lighting circuit at the circuit breaker (not for AutoTest or DALI versions).

Battery pack shall be replaced if the specified 3 hour duration is not met.

For replacement battery pack contact Philip Payne Ltd.

The light source contained in this luminaire shall only be replaced by the manufacturer or his service agent or a similar qualified person.

# **Important-Safety**

Before carrying out any servicing on this luminaire, ensure that the mains supply is fully isolated.

Disconnect luminaire before insulation testing of the installation.



# **Philip Payne Ltd**

A SUBSIDIARY OF F.W. THORPE PLC

Thornhill Road, Solihull, B91 2HB, England.

Fax: 0121 711 2469
e-mail: mail@philippayne.co.uk
Website: http://www.philippayne.co.uk
Philip Payne Ltd registered in England No. 1361523









ISO9001 FM55077

21LFT078\_4