

CE	F	LED	0.35 KG	EN60598-1	EN61547
NM	20	65	XT	EN60598-2-22	EN61000-3-2
				EN55015	PC ABS



TYKT 885 | PHILIP PAYNE



			Wall to Luminaire 	Luminaire to Luminaire 	Lumen Output	Wattage	Drive Current	Dimensions
TYKT885XT	1.2m escape route with 10.8 Lux average and 1 Lux minimum	NFPA101	4.7m	9.8m	555	4 Watts	700mA	
	Open Area with 10.8 Lux average and 1 Lux minimum	NFPA101	2.9m	7.2m	555	4 Watts	700mA	
TYKP885XT Head assembly IP rated beneath ceiling *	1.2m escape route with 10.8 Lux average and 1 Lux minimum	NFPA101	4.7m	9.8m	555	4 Watts	700mA	
	Open Area with 10.8 Lux average and 1 Lux minimum	NFPA101	2.9m	7.2m	555	4 Watts	700mA	

* Installer to ensure IP integrity to ceiling