



Printed on: 16 Oct 2015

Registration No. 2269
Title IP54 Emergency Exit Sign with Two Lighting Circuits (LED)
Status Authorised For Use
Supersedes ProductID N/A
Superseded By ProductID N/A
Date Authorised for Use 29 Jan 2014
Primary Use Suitable for sub-surface, non-public locations where CEPS and LEPS supplies exist.
Additional Info/KeyWords The product meets the LU Standard 1-085, and can be installed in sub-surface locations. The circuit faults are shown visible on adjacent lamps, and each circuit has an individual fuse-link. A special tool is supplied to remove front cover for access. Manufacturer: Philip Payne Ltd, Thornhill Road, Lode Lane, Solihull, B91 2HB. Tel: 0121 705 2384 Could be eligible for an Enhanced Capital Allowance ECA
Classification Hierarchy Electrical
 Stn Lighting & Pwr AC Only
Manufactured By Philip Payne Limited

Requirements

ReqID	Requirement	Status	Trial
No records to display.			

Conditions

Description	Linked To ReqID
No records to display.	

Evidence

EvidenceText	EvidenceType	FileName	Linked To ReqID
Datasheet	Specification	LUL300_RANGE_6.pdf	

Reminder: Products must not be publicised as being authorised for use by London Underground Limited (LUL) without also stating any conditions or limitations that apply, nor may any LUL intellectual property rights (such as the roundel trademark) be used in any such publicity. LUL reserves the right to withdraw authorisation of any product publicised in breach of this reminder. Refer to Web site www.lu-app.co.uk to check current status, download attachments and for details of other products.

MAYOR OF LONDON