

Kitemark™ Certificate

This is to certify that:

Philip Payne Ltd
Thornhill House
Thornhill Road
Lode Lane
Solihull
B91 2HB
United Kingdom

Holds Certificate Number:

KM 587259

In respect of:

BS EN 60598-2-22
Emergency luminaires

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.



For and on behalf of BSI:

Shahm Barhom, Group Product Certification Director

First Issued: 2013-04-25

Latest Issue: 2023-05-02

Effective Date: 2023-05-02

Expiry Date: 2023-12-17



Page: 1 of 4

Kitemark™ Certificate

No. KM 587259

Emergency Luminaires to BS EN 60598-2-22:2014+A1:2020 in conjunction with BS EN 60598-1:2021

Mini Cylinder range of Luminaires

BSI Test Report Numbers: 8750154, 3719060, 3718979

Rating: 220-240 V, 50/60 Hz, Class I, IP20

Brand	Model	Type	Version
Philip Payne	250MCSHDA	Surface mounted wall	Central battery DALI
	250MCSHLE	Surface mounted wall	Central battery
	250MCSHLM	Surface mounted wall	Self-contained
	250MCSHDL	Surface mounted wall	DALI
	250MCSHYL	Surface mounted wall	Auto test
	250MCSVDA	Surface mounted ceiling	Central battery DALI
	250MCSVLE	Surface mounted ceiling	Central battery
	250MCSVLM	Surface mounted ceiling	Self-contained
	250MCSVDL	Surface mounted ceiling	DALI
	250MCSVYL	Surface mounted ceiling	Auto test
	250MCRVDA	Recessed ceiling	Central battery DALI
	250MCRVLE	Recessed ceiling	Central battery
	250MCRVLM	Recessed ceiling	Self-contained
	250MCRVDL	Recessed ceiling	DALI
	250MCRVYL	Recessed ceiling	Auto test
	250MCRHDA	Recessed wall	Central battery DALI
	250MCRHLE	Recessed wall	Central battery
	250MCRHLM	Recessed wall	Self-contained
	250MCRHDL	Recessed wall	DALI
	250MCRHYL	Recessed wall	Auto test

First Issued: 2013-04-25

Latest Issue: 2023-05-02

Effective Date: 2023-05-02

Expiry Date: 2023-12-17

Page: 2 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Kitemark™ Certificate

No. KM 587259

Emergency Luminaires to BS EN 60598-2-22:2014+A1:2020 in conjunction with BS EN 60598-1:2021

LED Ceiling Recessed Luminaires

BSI Test Report numbers: 8607983, 3719062

Rating: 220-240 V, 50/60 Hz, Class II, IP20 above the ceiling / IP65 below the ceiling

Model	Mounting Type	Duration	Version
TYKT870LA	Recess Ceiling	Dependent on Battery system	Central Battery
TYKT870DA	Recess Ceiling	Dependent on Battery system	Central Battery DALI
TYKP870LA	Recess Ceiling	Dependent on Battery system	Central Battery
TYKP870DA	Recess Ceiling	Dependent on Battery system	Central Battery DALI

First Issued: 2013-04-25

Latest Issue: 2023-05-02

Effective Date: 2023-05-02

Expiry Date: 2023-12-17

Page: 3 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Kitemark™ Certificate

No. KM 587259

Emergency Luminaires to BS EN 60598-2-22:2014+A1:2020 in conjunction with BS EN 60598-1:2021

LED Ceiling Recessed Luminaires

BSI Test Report numbers: 8607983, 3719061.

Rating: 220-240 V, 50/60 Hz, Class II, IP20 above the ceiling / IP65 below the ceiling

Model	Mounting Type	Duration	Version
TYKT870LN	Recess Ceiling	3 Hrs	Self contained
TYKT870YS	Recess Ceiling	3 Hrs	Self contained Autotest
TYKT870DS	Recess Ceiling	3 Hrs	Self contained DALI
TYKP870LN	Recess Ceiling	3 Hrs	Self contained
TYKP870YS	Recess Ceiling	3 Hrs	Self contained Autotest
TYKP870DS	Recess Ceiling	3 Hrs	Self contained DALI

First Issued: 2013-04-25

Latest Issue: 2023-05-02

Effective Date: 2023-05-02

Expiry Date: 2023-12-17

Page: 4 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.